

CORRIGENDUM – 1

Subject : Corrigendum No. 1 dated 30.06.2020
Modification in Chapter –II “Explanatory Note”

E-Tender No : RailTel/WR/E-Tender/OT/2020-21/AC Dt. 17.06.2020

Name of the Work :- Design, Supply, Installation, Testing and Commissioning work of Precision Air Conditioner Plant at RCIL's Telecom PoP at Mahalaxmi, Mumbai

NOTE :- Please submit your offer, as per revised Explanatory note (for item No. 1), given in Chapter-II here below :-

Revised Explanatory note for schedule of items :-

SOR Item No.	Item Description (existing entry at page 115)	Item Description (to be read as)
1	Supply of 10 TON Precision Air Conditioning Plant (PAC) (VERTIV,DENCO,SCHNEIDER,STULZ or DELTA Make) Direct Expansion (DX) type PDX units with Copper condenser unit EC Motor and scroll compressor, with Capacity 33kW Gross Cooling Capacity, upper Discharge, Refrigerant R410A. Suitable to maintain temp 24+/-1C and Relative Humidity 50+/-5 in server room and provision of sequential programmable timer arrangement for auto ON/OFF operations (1W+1S) mode. Unit contains: 1. infrared Humidifier 2. G4 filtration	Supply of 10 TON Precision Air Conditioning Plant (PAC) (VERTIV,DENCO,SCHNEIDER,STULZ or DELTA Make) Direct Expansion (DX) type PDX units with Copper condenser unit EC Motor and scroll compressor, with Capacity 33kW Gross Cooling Capacity, Bottom Discharge, Refrigerant R410A. Suitable to maintain temp 24+/-1C and Relative Humidity 50+/-5 in server room and provision of sequential programmable timer arrangement for auto ON/OFF operations (1W+1S) mode. Unit contains: 1. infrared Humidifier 2. G4 filtration

Note :- 1. All other terms and conditions of Tender shall remain same.
2. For submission of Bid, please refer revised explanatory Note (for SOR item No.1).