

Tender No.	RCILSIGVKA-CHNOT7-09	Dept/Rly	CORPORATE OFFICE-DNM/RAILTEL CORPORATE OFFICE	Closing Date/Time	10/01/2023 15:00
Tender Title	Procurement of Diesel Generator Set 20 KVA, Single Phase, 23..... 				

ITEM

PL Code	Field Name	Existing Value	Modified Value
3	Warranty Period	2	12
3	Item Description	Supply of Diesel Generator Set 20 KVA, Single Phase, 230 V, 1500RPM, 50Hz, 30BHP (minimum) mounted with air cooled double cylinder diesel engine with acoustic enclosure complete silent type DG sets confirming to RDSO Specn. No. IRS(S) 69/86 with latest amendment. (CPCB Noise and Emission Complaint) Kirloskar make engine/alternator. This also include supply of standard AMF control panel, supply of 12V/120 AH battery set along with battery charger of suitable rating for charging the batteries to ensure self starting arrangement of DG Sets. This include Supply and installation of Change over switch 200 Amp. 3 Phase, 415VAC, 50Hz (Side Handle) four pole, Make Havel's IHCFE 200 or superior. It also includes supply of start/stop buttons, Volt/Ampere/Frequency meters and 63 AMP MCB(minimum). (Inspection by Consignee). Note: DG set will be procured from OEM or authorised dealer of OEM's with the warranty certificate of minimum 1 year .ALL masonry work required for installation of DG set will be done by contractor under supervision/instructions issued by site engineer in charge of RCIL.	Supply of Diesel Generator Set 20 KVA, Single Phase, 230 V, 1500RPM, 50Hz, 30BHP (minimum) mounted with air cooled double cylinder diesel engine with acoustic enclosure complete silent type DG sets confirming to RDSO Specn. No. IRS(S) 69/86 with latest amendment. (CPCB Noise and Emission Complaint) Kirloskar make engine/alternator. This also include supply of standard AMF control panel, supply of 12V/120 AH battery set along with battery charger of suitable rating for charging the batteries to ensure self starting arrangement of DG Sets. This include Supply and installation of Change over switch 200 Amp. 3 Phase, 415VAC, 50Hz (Side Handle) four pole, Make Havel's IHCFE 200 or superior. It also includes supply of start/stop buttons, Volt/Ampere/Frequency meters and 63 AMP MCB(minimum). (Inspection by Consignee). Note: DG set will be procured from OEM or authorised dealer of OEM's with the warranty certificate of minimum 1 year .ALL masonry work required for installation of DG set will be done by contractor under supervision/instructions issued by site engineer in charge of RCIL.

Published By **RICHA RANI**
Manager/Tech