



Corrigendum-II

Date: 15.12.2020

Sub: Tender for the work of "Provision of Battery Chargers and VRLA Battery sets for Telecom use of RailTel's OFC Network"

Ref: (i) E Tender No. RailTel/Tender/OT/CO/OP/2020-21/Bat.Chargers & Bat.Sets/535
dtd 19.11.2020.

(ii) Corrigendum-I dated: 14.12.20

With reference to above tender, following changes has been done:-

(i) Item description, SN-1, SOR: A-II , Chapter-1 will be read as:-

"230V AC/ 48V DC 200 Amp UC with 25 Amp (6+2) or 50 Amp (3+1), Single Phase SMPS based battery chargers with two (2) battery paths for Tubular Gel VRLA Maintenance free battery along with Lightning protection unit (LPU) and Surge protection device and DCDB (with all connecting materials) as per Technical Specification given in Chapter-4 of Tender Document."

(ii) SN A-2, SOR A-II, Technical Requirements & Specifications, Chapter-4 will be read as:-

"The technical specification of SMPS based power plant battery charger 48V/200 AMP Ultimate Capacity with 25 AMP (6+2) or 50 Amp (3+1) configuration, Single Phase with two battery paths for VRLA maintenance free batteries & Tubular Gel VRLA maintenance free batteries for telecom use should generally conforming to RDSO Specification No. RDSO/SPN/TL/23/99 (Ver 4) or Latest Or TEC spec No.GR/FLA/SMP-001/06 June 2010 with latest Amdt."

(iii) "Specification of cable for 25A Single Phase (6+2)", Scope of Installation , SN 2, (i), Special Note, Technical Requirements & Specifications, Chapter-4 will be read as:-

"Specification of cable for 25A Single Phase (6+2) / 50A Single Phase (3+1)"

All other terms & conditions are remained same.


(Vipin kumar)
Asst.GM/OP/CO
For Executive Director/Operations

रेलटेल कॉर्पोरेशन ऑफ इंडिया लिमिटेड (भारत सरकार का उपक्रम)
RailTel Corporation of India Ltd. (A Government of India Undertaking)

CIN : U64202DL2000GOI107905

Registered & Corporate Office : Plate-A, 6th Floor, Office Block, Tower-2, East Kidwai Nagar, New Delhi - 110023
T : +91 11 22900600, F +91 11 22900699 | Website : www.railtelindia.com