

RailTel Corporation of India Limited
(A Government of India Enterprise)
(Under Ministry of Railways)
Eastern Region, 3rd & 16th Floor, Chatterjee International Centre,
33A, Jawaharlal Nehru Road, Kolkata – 700 071

Phone: (033) 4400 – 9999/ 4404 – 1499

FAX: (033) 4400 – 9990

Addendum & Corrigendum – 1 Dt. 06.02.2019

RailTel/Tender/OT/ER/HQ/2017-18/1075/11012

Dt. 06.02.2019

Sub : Tender against the work of Supply, Installation & commissioning of 2.0 KVA On Line UPS at various locations in command area of South Eastern Coal field Ltd., Bilaspur in the states of Chatigarh & Madhya Pradesh ”

Ref : This office Tender No. Tender No. RailTel/Tender/OT/ER/HQ/2018-19/1075
Dt. 07.01.2019

With reference to the above Tender, the following Addendum & Corrigendum-1 is issued herewith:


Clause No. 19 of the Technical specification, Section-1, Chapter-5A (Page-20) of the Tender Document.:

Battery VAH capacity : minimum 4680 shall be corrected and read “Back up Battery capacity shall provide full load current for 2 hrs. minimum back up.”

Clause No.29 of the Technical specification, Section-1, Chapter-5A (Page-20) of the Tender Document

The UPS offered shall comply IS 16242 (Part-1): 2014. The manufacturer should have IS 18001 compliance.

All other terms & conditions given in the Tender Document remains unchanged.


Asstt. General Manager/Kolkata
for RailTel Corporation of India Ltd.