

**CORPORATE OFFICE-DNM/RAILTEL CORPORATE OFFICE
TENDER DOCUMENT**

Tender No: RCILSIGVKA-CHNOT9-11

Closing Date/Time: 10/01/2023 15:00

ED/RP/CO acting for and on behalf of The President of India invites E-Tenders against Tender No **RCILSIGVKA-CHNOT9-11** Closing Date/Time 10/01/2023 15:00 Hrs. Bidders will be able to submit their original/revised bids upto closing date and time only. Manual offers are not allowed against this tender, and any such manual offer received shall be ignored.

1. NIT HEADER

Bidding type	Normal Tender	Template	Normal
Contract type	Goods	Contract Category	Expenditure
Tender No	RCILSIGVKA-CHNOT9-11	Tender Type	Open - Indigenous
Evaluation Criteria	Itemwise	Bidding System	Single Packet
Pre-Bid Conference Required	No	Pre-Bid Conference Date Time	Not Applicable
Tendering Section	SIGNALLING		
Inspection Agency		Publishing Date / Time	16/12/2022 17:45
Bidding to be Done on	IREPS		
Procure From Approved Sources	No	Approving Agency	Not Applicable
Closing Date Time	10/01/2023 15:00		
Validity of Offer (Days)	60	Ranking Order for Bids	Lowest to Highest
Tender Doc. Cost (INR)	0.00	Earnest Money (INR)	41900.00
Tender Title	Procurement of Electrical (General) items in connection with "Up gradation of signalling from standard-I to standard-II(R) with Electronic Interlocking (EI) at 5 stations (i.e. Verka, Kathunangal, Jaintipura, Batala, Chhina) on ASR-PTK Section of Firozpur division".		

2. ITEM DETAILS

S.No.	PL Code (Group)	Item Type GST(Y/N)	Stock / NonStock	Ordering	Consider For Eval	Approving Agency	Inspection Agency	Currency Allowed	Estimated Rate
1	5 i	Goods (Y)	Non Stock	---	Yes		RDSO-QA	INR	
Description : Supply of active lightening arrestor of class 'A' for building protection as per standard NFC-17-102. It shall work on early streamer emission principle and shall be made of stainless steel with a T of 60 micro seconds. A non resettable type counter should also be supplied to count the number of lighting occurrences. It also includes supply of electrolytic copper tape of 25mm X 2mm of better to connecting class A devices to the earth pit. This includes installation, testing and commissioning of Class A device on top of the building. This device should be installed at suitable height on top of the building using a GI mask as per the instruction of RCIL engineer at site. The device should be connected to earth pit using a copper tape of 25mm X 2mm or better. This copper tape should be run firmly only the side of mask with the help of spacers. It shall also be ensured that the down conductor shall not touch the building throughout. The down conductor shall be connected to the earth electrode using exothermic welding. A counter shall be installed at appropriate space to count the number of occurrences. All the accessories like spares, welding material etc. required for installation shall be arranged by the contractor.(Inspection by RDSO). [Warranty Period: 2 Months after the date of delivery]									
Consignee			SR.MGR/TECH/CDG			Punjab		10.00 Numbers	
2	5 ii	Goods (Y)	Non Stock	---	Yes		CONSIGNEE	INR	
Description : Supply of Change over switch 200 Amp. 3 Phase, 415V AC, 50Hz (Side Handle) four pole, Make Havels IHCFFE 200 or superior. (Inspection by Consignee) [Warranty Period: 2 Months after the date of delivery]									
Consignee			SR.MGR/TECH/CDG			Punjab		10.00 Numbers	
3	5 iii	Goods (Y)	Non Stock	---	Yes		CONSIGNEE	INR	

**CORPORATE OFFICE-DNM/RAILTEL CORPORATE OFFICE
TENDER DOCUMENT**

Tender No: RCILSIGVKA-CHNOT9-11

Closing Date/Time: 10/01/2023 15:00

Description :Supply of 1.1 KV grade LT XL/PE . Insulated armored aluminum conductor cable, Making good the damages end termination with aluminum crimping socket/plugs. Provision of cable route markers etc. as required as per technical specification No. IS-7098. Size (2x70 Sq. mm). (Inspection by Consignee) [Warranty Period: 2 Months after the date of delivery]									
Consignee		SR.MGR/TECH/CDG			Punjab		1000.00 Metre		
4	5 iv	Goods (Y)	Non Stock	---	Yes		CONSIGNEE	INR	
Description :Laying of 1.1 KV grade LT XL/PE .Insulated armored aluminum conductor cable, Making good the damages end termination with aluminum crimping socket/plugs. Provision of cable route markers etc. as required as per technical specification. Size(2x70 Sq. mm). [Warranty Period: 2 Months after the date of delivery]									
Consignee		SR.MGR/TECH/CDG			Punjab		1000.00 Metre		
5	5 v	Goods (Y)	Non Stock	---	Yes		CONSIGNEE	INR	
Description :Supply of Control and Distribution panel for 10 KVA Auxiliary Transformer for Color light signaling supply in 25KV/AC traction system as per RDSO technical specification No-TL/SPC/PSI/CLS/0020(12/02 with A&C slips No 1 to 4 latest connection as required. (Inspection by Consignee) [Warranty Period: 2 Months after the date of delivery]									
Consignee		SR.MGR/TECH/CDG			Punjab		5.00 Numbers		
6	5 vi	Goods (Y)	Non Stock	---	Yes		CONSIGNEE	INR	
Description :Erection testing & commissioning of Control and Distribution panel for 10 KVA Auxiliary Transformer for Color light signaling supply in 25KV/AC traction system as per RDSO technical specification No-TL/SPC/PSI/CLS/0020(12/02 with A&C slips No 1 to 4 latest connection as required. [Warranty Period: 2 Months after the date of delivery]									
Consignee		SR.MGR/TECH/CDG			Punjab		5.00 Numbers		

3. T AND C

F.O.R

Description
Destination

Delivery Period

Description	Delivery / Completion	Rate of Supply
-------------	-----------------------	----------------

**CORPORATE OFFICE-DNM/RAILTEL CORPORATE OFFICE
TENDER DOCUMENT**

Tender No: RCILSIGVKA-CHNOT9-11

Closing Date/Time: 10/01/2023 15:00

Item - Supply of active lightening arrestor of class 'A' for building protection as per standard NFC-17-102. It shall work on early streamer emission principle and shall be made of stainless steel with a T of 60 micro seconds. A non resettable type counter should also be supplied to count the number of lighting occurrences. It also includes supply of electrolytic copper tape of 25mm X 2mm of better to connecting class A devices to the earth pit. This includes installation, testing and commissioning of Class A device on top of the building. This device should be installed at suitable height on top of the building using a GI mask as per the instruction of RCIL engineer at site. The device should be connected to earth pit using a copper tape of 25mm X 2mm or better. This copper tape should be run firmly only the side of mask with the help of spacers. It shall also be ensured that the down conductor shall not touch the building throughout. The down conductor shall be connected to the earth electrode using exothermic welding. A counter shall be installed at appropriate space to count the number of occurrences. All the accessories like spares, welding material etc. required for installation shall be arranged by the contractor.(Inspection by RDSO).	Commencement : Within 60 Days of issue of Contract, Completion : Within 60 Days	
Item - Supply of Change over switch 200 Amp. 3 Phase, 415V AC, 50Hz (Side Handle) four pole, Make Havels IHCFE 200 or superior. (Inspection by Consignee)	Commencement : Within 60 Days of issue of Contract, Completion : Within 60 Days	
Item - Supply of 1.1 KV grade LT XL/PE . Insulated armored aluminum conductor cable, Making good the damages end termination with aluminum crimping socket/plugs. Provision of cable route markers etc. as required as per technical specification No. IS-7098. Size (2x70 Sq. mm). (Inspection by Consignee)	Commencement : Within 60 Days of issue of Contract, Completion : Within 60 Days	
Item - Laying of 1.1 KV grade LT XL/PE .Insulated armored aluminum conductor cable, Making good the damages end termination with aluminum crimping socket/plugs. Provision of cable route markers etc. as required as per technical specification. Size(2x70 Sq. mm).	Commencement : Within 60 Days of issue of Contract, Completion : Within 60 Days	
Item - Supply of Control and Distribution panel for 10 KVA Auxiliary Transformer for Color light signaling supply in 25KV/AC traction system as per RDSO technical specification No-TL/SPC/PSI/CLS/0020(12/02 with A&C slips No 1 to 4 latest connection as required. (Inspection by Consignee)	Commencement : Within 60 Days of issue of Contract, Completion : Within 60 Days	
Item - Erection testing & commissioning of Control and Distribution panel for 10 KVA Auxiliary Transformer for Color light signaling supply in 25KV/AC traction system as per RDSO technical specification No-TL/SPC/PSI/CLS/0020(12/02 with A&C slips No 1 to 4 latest connection as required.	Commencement : Within 60 Days of issue of Contract, Completion : Within 60 Days	

Payment Terms

S.No	Description
------	-------------

**CORPORATE OFFICE-DNM/RAILTEL CORPORATE OFFICE
TENDER DOCUMENT**

Tender No: RCILSIGVKA-CHNOT9-11

Closing Date/Time: 10/01/2023 15:00

Payment Terms	
1	As per Tender Document

Statutory Variation Clause

S.No	Description
1	As per attached Tender Document.

Option Clause

S.No	Description
1	As per attached Tender Document.

Railway Standard Fall Clause

S.No	Description
1	As per attached Tender Document.

Standard Governing Conditions

S.No	Description
1	As per attached Tender Document.

4. ELIGIBILITY CONDITIONS

Standard Eligibility Criteria

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	As per Tender Document	No	No	Allowed (Optional)

5. COMPLIANCE CONDITIONS

Check List

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	As per attached Tender Document.	No	No	Not Allowed
2	As per attached Tender Document.	No	No	Not Allowed

Commercial-Compliance

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	Please enter the percentage of local content in the material being offered. Please enter 0 for fully imported items, and 100 for fully indigenous items. The definition and calculation of local content shall be in accordance with the Make in India policy as incorporated in the tender conditions.	No	Yes	Allowed (Optional)
2	As per Tender Document	No	No	Allowed (Mandatory)
3	As per Tender Document	No	No	Allowed (Mandatory)
4	As per attached Tender Document.	No	No	Allowed (Mandatory)

Special Conditions

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
-------	-------------	-----------------------	-----------------	---------------------

**CORPORATE OFFICE-DNM/RAILTEL CORPORATE OFFICE
TENDER DOCUMENT**

Tender No: RCILSIGVKA-CHNOT9-11

Closing Date/Time: 10/01/2023 15:00

1	As per attached Tender Document.	No	No	Not Allowed
2	As per attached Tender Document.	No	No	Not Allowed
3	As per attached Tender Document.	No	No	Not Allowed

Technical-Compliances

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	As per Tender Document	No	No	Allowed (Mandatory)
2	As per Tender Document	No	No	Allowed (Mandatory)
3	As per attached Tender Document.	No	No	Allowed (Mandatory)

Undertakings

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	As per attached Tender Document.	No	No	Not Allowed
2	As per attached Tender Document.	No	No	Not Allowed
3	As per attached Tender Document.	No	No	Not Allowed

6. DOCUMENTS ATTACHED WITH TENDER

S.No.	Document Name	Document Description
1	5.Tender_Store_ElectricalGen16.12.2022.pdf	Tender Document

7. RESPONSIVENESS

S.No.	Description
1	As per attached Tender Document.

This tender complies with Public Procurement Policy (Make in India) Order 2017, dated 15/06/2017, issued by Department of Industrial Promotion and Policy, Ministry of Commerce, circulated vide Railway Board letter no. 2015/RS(G)/779/5 dated 03/08/2017 and 27/12/2017 and amendments/ revisions thereof.

As a Tender Inviting Authority, the undersigned has ensured that the issue of this tender does not violate provisions of GFR regarding procurement through GeM.

Digitally Signed By

Manager/Tech (RICHA RANI)