

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	16-03-2023 15:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	16-03-2023 15:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	60 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Railways
Department Name/विभाग का नाम	Na
Organisation Name/संगठन का नाम	Railtel Corporation Of India Ltd
Office Name/कार्यालय का नाम	Railtel Corporation Of India Ltd Kolkata
Total Quantity/कुल मात्रा	2
Item Category/मद केटेगरी	Power Generator-DG Set (Upto 900 KVA) (Q2)
Minimum Average Annual Turnover of the bidder (For 3 Years)/बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का)	4 Lakh (s)
OEM Average Turnover (Last 3 Years)/मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का)	10 Lakh (s)
Years of Past Experience Required for same/similar service/उन्हीं/समान सेवाओं के लिए अपेक्षित विगत अनुभव के वर्ष	3 Year (s)
MSE Exemption for Years of Experience/अनुभव के वर्षों से एमएसई छूट/ and Turnover	No
Startup Exemption for Years of Experience/अनुभव के वर्षों से स्टार्टअप छूट/ and Turnover	No
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer

Bid Details/बिड विवरण	
Past Performance/विगत प्रदर्शन	40 %
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	No
Type of Bid/बिड का प्रकार	Two Packet Bid
Primary product category	Power Generator-DG Set (Upto 900 KVA)
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	5 Days
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Estimated Bid Value/अनुमानित बिड मूल्य	817200
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation

EMD Detail/ईएमडी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
EMD Amount/ईएमडी राशि	16400

ePBG Detail/ईपीबीजी विवरण

Advisory Bank	State Bank of India
ePBG Percentage(%) / ईपीबीजी प्रतिशत (%)	3.00
Duration of ePBG required (Months) / ईपीबीजी की अपेक्षित अवधि (महीने).	27

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy./जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कैटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने हैं। एमएसई कैटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

Beneficiary/लाभार्थी :

Asstt.GM Contracts

RailTel corporation of India Ltd., Eastern Region, 19th Floor, Aurora Waterfront Building, GN. 34/1, Block GN, Sector-V, Salt Lake City, Bidhannagar, Kolkata-700091, Ministry of Railways
(Puthenpurackal Devasia James)

Splitting/विभाजन

Bid splitting not applied.

MII Purchase Preference/एमआईआई खरीद वरीयता

MII Purchase Preference/एमआईआई खरीद वरीयता	Yes
--	-----

MSE Purchase Preference/एमएसई खरीद वरीयता

MSE Purchase Preference/एमएसई खरीद वरीयता	Yes
---	-----

1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
2. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
3. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
4. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .In case Buyer has selected Purchase preference to Micro and Small Enterprises clause in the bid, the same will get precedence over this clause.
5. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total QUANTITY.
6. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any

impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

7. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 40% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Power Generator-DG Set (Upto 900 KVA) (1 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Power Generator INSTALLATION CONFIGURATIONS	Power Generator installation configurations as defined in CPWD General Specifications for Electrical works - Part VII (DG Set)	Fixed (Power Generators are permanently installed)"
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (kVA)	15
	No of Phase (Single Phase-3-5kVA) (Single Phase or Three Phase-5 & 7-5, 10,15, 20, 25, 30 & 40 kVA) (Three Phase-50 to 900 kVA)	Single Phase
ENGINE	Rated Engine Power (kWm)	100 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator + Any Auxiliary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficiency, 110 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator Any Auxiliary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficiency Or higher
	Type of Engine cooling	Liquid Cooled
	Type of governer	Electronic Or higher
	Rated RPM of Engine (RPM)	1500
	Fuel	High Speed Diesel (HSD)
	Starting voltage (volt)	12
ALTERNATOR	Conformity to Indian Standard (for Alternator)	Generally conforming to IS:13364 (Part-1) latest (Upto 20 kVA)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Voltage Regulation Grade	VG 3 Or higher
	Alternator IP Rating	IP 23 Or higher
CONTROL PANEL	Control Panel	AMF Control Panel
	Control Panel Location	Inside the canopy
	Other devices in the control panel (with appropriate rating) - inclusive in the scope of supply	Required switches and cutout, MCB, MCCB, Circuit breaker, Battery charger
BATTERY	Battery Type & Specification	"Low Maintenance free to IS: 14257 for high cranking performance"
TRAILER	Trailer	NA for Fixed/Skid Mounted Power Generator
	Pay load of the Trailer	0, 500, 1000, 2000 Or higher
SCOPE OF INSTALLATION	Installation	with installation - inclusive in the scope of supply Or higher
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-1)	a) Installation of Power Generator when offered by the vendor is inclusive in the scope of supply and shall be done by the seller. The installation work of Power Generator and its constituent parts shall be generally conforming to CPWD General Specification for Electrical Works, Part - VII - latest. b) Foundation shall be constructed by the seller. Foundation shall be of PCC type with the ratio of 4:2:1. The length and breadth of the foundation shall be 300 mm more from the respective length and breadth of the Power Generator. The height of the foundation shall be 400 mm, i.e., 200 mm below and 200 mm above the ground level. All the materials / labour required for foundation work shall be supplied by the seller.
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-2)	c) Supply, laying and termination of interconnecting power and control cable shall be done by the seller. The cable supplied shall be ISI marked heavy duty PVC insulated, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with aluminium conductor having insulation of PVC compound type -C, suitable for rated voltage upto and including 1100 volts and conforming to IS: 1554 (Part-1) latest. For 3-Phase Power Generators, 3.5 core or higher core cables shall be used. Total length of the cable supplied by the seller shall be within 30 meters for each Power Generator with manual control panel and within 60 metres for each Power Generator with AMF control panel. The current rating of the cables shall be as indicated below: 2C, 6 Sq mm for Single Phase, 3.5 & 5.0 KVA 2C, 10 Sq mm for Single Phase, 7.5 & 10 KVA 2C, 25 Sq mm for Single Phase, 15 KVA 2C, 35 Sq mm for Single Phase, 20 KVA 2C, 70Sq mm for Single Phase, 25 KVA 2C, 95Sq mm for Single Phase, 30 KVA 2C, 120Sq mm for Single Phase, 40 KVA 4C, 4 Sq mm for Three Phase,

Specification	Specification Name/विशिष्ट का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-3)	d) 10 KVA 4C, 6 Sq mm for Three Phase, 15 KVA 4C, 10 Sq mm for Three Phase, 20 & 25 KVA 4C, 16 Sq mm for Three Phase, 30 KVA 3.5C, 25 Sq mm for Three Phase, 40 KVA 3.5C, 35 Sq mm for Three Phase, 50 KVA 3.5C, 70 Sq mm for Three Phase, 62.5 & 75 KVA 3.5C, 95 Sq mm for Three Phase, 82.5 KVA 3.5C, 120 Sq mm for Three Phase, 100 KVA 3.5C, 185 Sq mm for Three Phase, 125 KVA 3.5C, 300 Sq mm for Three Phase, 160 KVA 3.5C, 2 Run of 120 Sq mm for Three Phase, 180 KVA 3.5C, 2 Run of 150 Sq mm for Three Phase, 200 KVA 3.5C, 2 Run of 185 Sq mm for Three Phase, 225 KVA 3.5C, 2 Run of 240 Sq mm for Three Phase, 250 & 275 KVA 3.5C, 3 Run of 185 Sq mm for Three Phase, 320 KVA 3.5C, 3 Run of 240 Sq mm for Three Phase, 380 & 400 KVA 3.5C, 4 Run of 240 Sq mm for Three Phase, 500, 600 & 750 KVA 3.5C, 6 Run of 240 Sq mm for Three Phase, 900 KVA
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-4)	e) Construction of suitable earthing station and necessary connections shall be done by the seller. All the materials / labour required for construction of earthing station shall be supplied by the seller. The total number of earthing pits/stations shall be 4, i.e., 2 for neutral and 2 for body-earthing. Netutral earthing shall be done with copper Plate and Body earthing shall be done with G.I. plate / Copper. The consignee should choose installation site in such a way that the earthing stations can be made within 10 metres of the Power Generator. Earthing station shall be typically constructed as per prevalent standard practices and shall be generally conforming to CPWD General specification for Electrical Works, Part - VII & Part - I - latest. e) Installation of Fuel Tank including foundation / stand shall be done by the seller. f)The warranty is applicable upto specified value of month/hours whichever occurs first's.
	Above Scope of installation for Diesel Generating Set when offered by the vendor has been seen, read, understood and agreed to comply	Yes
WARRANTY/SERVICE S	Warranty on Complete power genertor/DG Set	24, 36 Or higher
	Number of preventive maintenance visits offered in an year during warranty period (Supply of all consumables is the buyer's responsibilty)*	2, 3
TEST REPORTS	Test report Available for (Test/approval)	Type Approval Certificate for the specified rating of the Power Generator from any of the designated agency authorized by CPCB, COP Certificate for engine, Type test report and Endurance test report for Engine as per IS: 10001 latest / IS: 10002 latest, Type test report for Alternator as per IS:13364 (Part-1) latest / IS:13364 (Part-2) latest to prove conformity to the specifications

Additional Specification Parameters - Power Generator-DG Set (Upto 900 KVA) (1 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Eligibility Criteria, other terms and conditions, detailed Technical Specification	Eligibility Criteria, other terms and conditions, detailed Technical Specification are available in 'Buyer uploaded ATC document' . The DG set shall be supplied Installed & commissioned at RailTel PoP, Bhadrak Railway Station.

* Bidders offering must also comply with the additional specification parameters mentioned above.

Installation Commissioning and Testing (ICT) details for the above item:

% of Product Cost Payable on Product Delivery	70%
Min Cost Allocation for ICT as a % of product cost	30%
Number of days allowed for ICT after site readiness communication to seller	30 Days/दिन

Consignees/Reporting Officer/परेषितो/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषितो/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Bandaru Manohar	751023,1st Floor, Annex Building, B-Block, Rail Vihar, Chandrasekharapur, Bhubaneswar	1	45

Power Generator-DG Set (Upto 900 KVA) (1 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

[* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Power Generator INSTALLATION CONFIGURATIONS	Power Generator installation configurations as defined in CPWD General Specifications for Electrical works - Part VII (DG Set)	Fixed (Power Generators are permanently installed)"
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (kVA)	25
	No of Phase (Single Phase-3-5kVA) (Single Phase or Three Phase-5 & 7-5, 10,15, 20, 25, 30 & 40 kVA) (Three Phase-50 to 900 kVA)	Three Phase
ENGINE	Rated Engine Power (kWm)	100 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator + Any Auxiliary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficiency, 110 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator Any Auxiliary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficiency Or higher
	Type of Engine cooling	Liquid Cooled
	Type of governer	Electronic Or higher
	Rated RPM of Engine (RPM)	1500
	Fuel	High Speed Diesel (HSD)
ALTERNATOR	Alternator Voltage Rating	415.0
	Conformity to Indian Standard (for Alternator)	Generally conforming to IS:13364 (Part-1) latest (Upto 20 kVA), Generally conforming to IS:13364 (Part-2) latest (Above 20 KVA)
	Voltage Regulation Grade	VG 3 Or higher
	Alternator IP Rating	IP 23 Or higher
CONTROL PANEL	Control Panel	AMF Control Panel
	Control Panel Location	Inside the canopy
	Other devices in the control panel (with appropriate rating) - inclusive in the scope of supply	Required switches and cutout, MCB, MCCB, Contactor, Circuit breaker, Battery charger
BATTERY	Battery Type & Specification	"Low Maintenance free to IS: 14257 for high cranking performance"
TRAILER	Trailer	NA for Fixed/Skid Mounted Power Generator
	Pay load of the Trailer	0, 500, 1000, 2000 Or higher
SCOPE OF INSTALLATION	Installation	with installation - inclusive in the scope of supply Or higher

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-1)	a) Installation of Power Generator when offered by the vendor is inclusive in the scope of supply and shall be done by the seller. The installation work of Power Generator and its constituent parts shall be generally conforming to CPWD General Specification for Electrical Works, Part - VII - latest. b) Foundation shall be constructed by the seller. Foundation shall be of PCC type with the ratio of 4:2:1. The length and breadth of the foundation shall be 300 mm more from the respective length and breadth of the Power Generator. The height of the foundation shall be 400 mm, i.e., 200 mm below and 200 mm above the ground level. All the materials / labour required for foundation work shall be supplied by the seller.
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-2)	c) Supply, laying and termination of interconnecting power and control cable shall be done by the seller. The cable supplied shall be ISI marked heavy duty PVC insulated, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with aluminium conductor having insulation of PVC compound type -C, suitable for rated voltage upto and including 1100 volts and conforming to IS: 1554 (Part-1) latest. For 3-Phase Power Generators, 3.5 core or higher core cables shall be used. Total length of the cable supplied by the seller shall be within 30 meters for each Power Generator with manual control panel and within 60 metres for each Power Generator with AMF control panel. The current rating of the cables shall be as indicated below: 2C, 6 Sq mm for Single Phase, 3.5 & 5.0 KVA 2C, 10 Sq mm for Single Phase, 7.5 & 10 KVA 2C, 25 Sq mm for Single Phase, 15 KVA 2C, 35 Sq mm for Single Phase, 20 KVA 2C, 70Sq mm for Single Phase, 25 KVA 2C, 95Sq mm for Single Phase, 30 KVA 2C, 120Sq mm for Single Phase, 40 KVA 4C, 4 Sq mm for Three Phase,
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-3)	d) 10 KVA 4C, 6 Sq mm for Three Phase, 15 KVA 4C, 10 Sq mm for Three Phase, 20 & 25 KVA 4C, 16 Sq mm for Three Phase, 30 KVA 3.5C, 25 Sq mm for Three Phase, 40 KVA 3.5C, 35 Sq mm for Three Phase, 50 KVA 3.5C, 70 Sq mm for Three Phase, 62.5 & 75 KVA 3.5C, 95 Sq mm for Three Phase, 82.5 KVA 3.5C, 120 Sq mm for Three Phase, 100 KVA 3.5C, 185 Sq mm for Three Phase, 125 KVA 3.5C, 300 Sq mm for Three Phase, 160 KVA 3.5C, 2 Run of 120 Sq mm for Three Phase, 180 KVA 3.5C, 2 Run of 150 Sq mm for Three Phase, 200 KVA 3.5C, 2 Run of 185 Sq mm for Three Phase, 225 KVA 3.5C, 2 Run of 240 Sq mm for Three Phase, 250 & 275 KVA 3.5C, 3 Run of 185 Sq mm for Three Phase, 320 KVA 3.5C, 3 Run of 240 Sq mm for Three Phase, 380 & 400 KVA 3.5C, 4 Run of 240 Sq mm for Three Phase, 500, 600 & 750 KVA 3.5C, 6 Run of 240 Sq mm for Three Phase, 900 KVA

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-4)	e) Construction of suitable earthing station and necessary connections shall be done by the seller. All the materials / labour required for construction of earthing station shall be supplied by the seller. The total number of earthing pits/stations shall be 4, i.e., 2 for neutral and 2 for body-earthing. Netutral earthing shall be done with copper Plate and Body earthing shall be done with G.I. plate / Copper. The consignee should choose installation site in such a way that the earthing stations can be made within 10 metres of the Power Generator. Earthing station shall be typically constructed as per prevalent standard practices and shall be generally conforming to CPWD General specification for Electrical Works, Part - VII & Part - I - latest. e) Installation of Fuel Tank including foundation / stand shall be done by the seller. f)The warranty is applicable upto specified value of month/hours whichever occurs first's.
	Above Scope of installation for Diesel Generating Set when offered by the vendor has been seen, read, understood and agreed to comply	Yes
WARRANTY/SERVICE S	Warranty on Complete power genertor/DG Set	24, 36 Or higher
	Number of preventive maintenance visits offered in an year during warranty period (Supply of all consumables is the buyer's responsibilty)*	2
TEST REPORTS	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	Certificates required as per CPCB
	Test report Available for (Test/approval)	Type Approval Certificate for the specified rating of the Power Generator from any of the designated agency authorized by CPCB, COP Certificate for engine, Type test report for Alternator as per IS:13364 (Part-1) latest / IS:13364 (Part-2) latest to prove conformity to the specifications
	Agree to provide all relevant documents Test Report/supporting document /reports etc to the buyer at the time of bidding or on demand	YES

Additional Specification Parameters - Power Generator-DG Set (Upto 900 KVA) (1 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Eligibility Criteria, other terms and conditions, detailed Technical Specification	Eligibility Criteria other terms and conditions, detailed Technical Specification are available in 'Buyer uploaded ATC document'. The DG set shall be supplied Installed & commissioned at RailTel PoP, Bhubaneswar Railway Station.

* Bidders offering must also comply with the additional specification parameters mentioned above.

Installation Commissioning and Testing (ICT) details for the above item:

% of Product Cost Payable on Product Delivery	70%
Min Cost Allocation for ICT as a % of product cost	30%
Number of days allowed for ICT after site readiness communication to seller	30 Days/दिन

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Bandaru Manohar	751023,1st Floor, Annex Building, B-Block, Rail Vihar, Chandrasekharapur, Bhubaneswar	1	45

Buyer Added Bid Specific Terms and Conditions/क्रता द्वारा जोड़ी गई बिड की विशेष शर्तें**1. Generic**

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

2. Generic

Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.

3. Generic

Experience Criteria: The Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for 3 years before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the primary product having highest value should meet this criterion.

4. Generic

Manufacturer Authorization:Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

5. Inspection

Pre-dispatch inspection at Seller premises (Fee/Charges to be borne by the BUYER):Before dispatch, the goods will be inspected by Buyer / Consignee or their Authorized Representative or by Nominated External Inspection Agency (independently or jointly with Buyer or Consignee as decided by the Buyer) at Seller premises (or at designated place for inspection as declared / communicated by the seller) for their compliance to the contract specifications. Fee/Charges taken by the External inspection Agency and any external laboratories testing charges shall be borne by the Buyer. For in-house testing, the Sellers will provide necessary facilities free of cost. Seller shall notify the Buyer through e-mail about readiness of goods for pre-dispatch inspection and Buyer will notify the Seller about the Authorized Representative/ Nominated External Inspection Agency and the date for testing. The goods would be dispatched to consignee only after clearance in pre-dispatch inspection. Consignee's right of rejection as per GTC in respect of the goods finally received at his location shall in no way be limited or waived by reason of the goods having previously been inspected, tested and passed by Buyer/ Consignee or its Nominated External Inspection Agency prior to the goods' shipment. While bidding, the sellers should take into account 7 days for inspection from the date of email offering the goods for inspection. Any delay in inspection beyond 7 days shall be on the part of the buyer and shall be regularised without Liquidated Damages.

When there is requirement of submission the advance sample, the seller shall inform the buyer promptly through emails about the date of submission of sample to the buyer nominated Inspection agency.

6. Scope of Supply

Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

7. Certificates

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

8. Warranty

Warranty period of the supplied products shall be 2 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

9. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. Any clause(s) incorporated by the Buyer regarding following shall be treated as null and void and would not be considered as part of bid:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum

issued by DPIIT in this regard.

2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process.
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।

---Thank You/धन्यवाद---